

CVA

ORDINANCE NO. 54

ORDINANCE AMENDING THE EAST NORRITON TOWNSHIP PLUMBING CODE
KNOWN AS ORDINANCE NO. 52

The Supervisors of East Norriton Township hereby Ordain and Enact as follows:

The East Norriton Township Plumbing Code, known as Ordinance No. 52 is hereby supplemented and amended as follows:-

CHANGES IN PART I

- 2 (e) Registration fees, - the following is added:
"Cesspool Cleaner \$5.00"
- 3 (c) Board of Examiners, - the word "resident" is deleted in paragraphs one and two.

CHANGES IN PART II

- 3 General Regulations, second paragraph of
 - (a) Grade of Horizontal Piping shall now read
"In general, the slope for all pipes shall be 1/4" fall per foot or greater, unless otherwise approved by the plumbing official."
 - (t) Individual or Private Sewage -Disposal Systems, shall now read,
"When a public sewer is not available for use, sewage and drainage piping shall be connected to an individual sewage disposal system as specified and provided in Act. No. 537 approved January 24, 1966, Act of 1965, P.L.1535."
- 4 Quality and Weight of Materials
 - (f) Permitted Uses, - the following changes are made in the reference table
"Asbestos Cement Sewer Pipe is deleted
Copper Tube D.W.& V. is deleted and in its place is added Copper Tube Type M."
- 5 Joints and Connections
 - (g) Cast Iron, - shall now read
"Cast Iron joints may be either caulked or screw joints. Approved neoprene joints may be used for underground use only."

6. Traps and Clean Outs

(f) Traps, Kind and Minimum Size, - the first two sentences shall now read

"Every trap shall be self-cleaning. Traps for bathtubs shall conform to Philadelphia regulations; traps for lavatories, sinks, and other similar fixtures shall be of lead, brass, cast iron, or of malleable iron galvanized or porcelain enameled inside."

The table of minimum size traps and waste branches is changed so that

"Bath, shower, stall shall read 2" instead of 1½" "

7. Water Supply and Distribution

(c) House Water Lines, - is changed by adding the following

"Minimum size to last three (3) fixtures shall be ½". Branches shall be ½". All other lines shall be ¾" (See (e) below).

8. Hangers and Supports

(b) Horizontal Piping, - is changed by adding the following

"(See Pipe Hangers (d))"

11. Soil Waste and Vent Pipes

(a) Material (1) shall now read

"(1) Underground Piping. All sanitary drains when underground shall be extra heavy cast iron pipe and shall be of lead or acid resisting cast iron where necessary for corrosive industrial wastes. Short branch soil or waste connections may also be of lead pipe. Building sewers shall be of cast iron or clay in accordance with sewer authority requirements."

(b) Fixture Units is changed so that the minimum, nominal drain and trap diameter of "1 shower stall, shower head only, Class 1 shall be 2" instead of 1½" "

(1) Distance of Vent from Fixtures, - the word "horizontal" shall be deleted.

12 Building Drains and Sewers

(e) Size of Building Sewers, Building Drains, and Horizontal Branches, - the tables designated "House Drain and House Sewers (Sanitary only)" and "Horizontal Branches (Sanitary Only)" are changed so that from each is deleted the entire column designated "1/8" Fall per foot."

This Ordinance shall become effective immediately.

All Ordinances or parts of Ordinances inconsistent with or in conflict with this Ordinance be and the same are hereby repealed.

Ordained and Enacted this 8 day of July, 1968.

Attest: Calvin Smith
Secretary

William E. King
Chairman, Board of Supervisors