



NOTE: WHERE THE SIDEWALK ABUTS CURB OR OTHER PERMANENT STRUCTURES, PLACE AN 1/2" EXPANSION JOINT. PROVIDE 1/2" TOOLED CONTRACTION JOINTS AT MAXIMUM 4'-0" SPACING. PROVIDE 1/2" EXPANSION JOINTS AT MAXIMUM 20'-0" SPACING.

Dwg. Name: 05947578.DWG Last Revised: 05/30/06 13:12

EAST NORRITON TOWNSHIP



270 Granite Run Drive
Lancaster, Pennsylvania 17601
Tel 717.569.7021

CONCRETE SIDEWALK DETAIL

DATE: MAY 2006

DETAIL: 6