



# East Norriton Township Police Department

## GENERAL ORDER 3.1.3

### FIRE DETECTION/SUPPRESSION SYSTEMS

**Subject:**

Cell Areas

**Issued Date:**

March 23, 2011

**Effective Date:**

March 23, 2011

**Revised Date:**

April 18, 2017

**PLEAC STANDARD Reference**

3.1.3, 3.2.4

**Index Words**

Safety-Fire Alarm and Smoke Detection

### 3.1.3 Fire Detection/Suppression Systems

- A. Located within the East Norriton Township Police facility are various types of fire suppression equipment. This equipment includes automatic fire alarms, a heat and smoke detection system and firefighting equipment. This equipment is maintained by the Township of East Norriton and is tested by the Fire Marshal or a member of the Norriton Fire Engine Company. The testing or maintenance is conducted on:
1. Over-head sprinkler systems.
  2. Wall mounted fire suppression equipment.
- B. The fire prevention plan includes:
1. No smoking in the cell area. The East Norriton Township building is a "No Smoking" building. No matches, lighters or fire ignition/initiating devices shall be used in the building.
  2. A weekly documented inspection of the cell area including visual inspection of fire equipment shall be conducted by the Sergeant of Detectives or designee.
  3. Annual documented testing of fire suppression equipment, including fire extinguishers.
  4. Daily documented visual inspection of the automatic fire detection devices and alarm systems.
  5. Documented testing of the automatic fire detection devices and alarm systems in accordance with law and local fire code regulations.
- C. Audible alarm systems, including water flow alarms, and heat and smoke detection devices will notify the Communications Center of an alarm.

By order of:

A handwritten signature in cursive script, appearing to read "Brandon Pasquale".

Brandon Pasquale  
Chief of Police