

ORDINANCE NO. 328

EAST NORRITON TOWNSHIP

MONTGOMERY COUNTY, PENNSYLVANIA

AN ORDINANCE AMENDING THE CODE OF EAST NORRITON TOWNSHIP, SPECIFICALLY, CHAPTER 73, ENTITLED "PLUMBING" BY AMENDING SECTION P-403.0 WHICH REGULATES THE TYPE OF MATERIAL USED FOR SANITARY SEWER LINES WITHIN THE TOWNSHIP.

THE BOARD OF SUPERVISORS OF EAST NORRITON TOWNSHIP, MONTGOMERY COUNTY, PENNSYLVANIA, UNDER AND BY VIRTUE OF THE AUTHORITY GRANTED BY THE SECOND CLASS TOWNSHIP CODE, DOES HEREBY ENACT AND ORDAIN:

SECTION 1.

Section P-403.0 is amended by adding:

Section P-403.6, Sanitary Sewer Mains

All installation of sanitary sewer pipe and lateral connections and pipe shall be polyvinylchloride (PVC) plastic gasketed pipe, Type SDR 35. Where the depth of sewer pipe crown is greater than 12 feet or within areas of high groundwater (flood plain, stream crossings, wetlands) shall be Ductile Iron Class 52, cement line pipe, tyton joints. The entire sewer run, between manholes shall be ductile iron pipe, change of material shall not be permitted. All lateral connections shall be of the same material as the pipe. The requirement of mechanical joint or flex joint Ductile Iron Class 52 pipe will be made by the Township Engineer.

SECTION 2.

If any section, subsection, sentence, clause, phrase or portion of this Ordinance is for any reason held invalid or unconstitutional by any court of competent jurisdiction, such provision shall be separate, distinct and independent and such holding shall not affect the validity of the remaining portions of this Ordinance.

SECTION 3.

This Ordinance shall in no other way affect, amend or modify the Code of East Norriton Township.

ENACTED and ORDAINED by the Board of Supervisors of East Norriton Township, Montgomery County, Pennsylvania this ~~25<sup>th</sup>~~ day of JANUARY , 1993.

ATTEST:

BOARD OF SUPERVISORS OF  
EAST NORRITON TOWNSHIP

  
Secretary

BY:   
Chairman

plumcode.amd